

No.	<b>2019657-1</b>
Issuer's name	<b>OMB Saleri S.p.A.</b>
Issuer' address	Via Rose di Sotto – 38/c – 25126 – Brescia - Italy

Object of the declaration

**Safety gas connection valve – type 657** (with and without thermal shut-off device)

The undersigned OMB Saleri S.p.A. DECLARES under its own responsibility that the product in the object of the declaration, is manufactured in a workmanlike manner, in compliance and approved according to the requirements of the following documents:

Documents No.	Title	Edition/ Date of issue
NG-4606BL0374	DVGW type examination certificate	(see certificate)
14/1107/4606/126	DVGW laboratory test report	02/07/2014
CE-0085-CPD-CN0284	DVGW EC conformity certificate	09/11/2012
EN 15069:2010	Standard for: Safety gas connection valves for metal hose assemblies used for the connection of domestic appliances using gaseous fuel	July 2010
DIN 3586:2003	Thermally activated shutting-off devices for gas.	October 2003
Regulation (EU) No. 305/2011	Construction Products Regulation (CPR) is a harmonised rules for the marketing of construction products in the EU.	16/06/2014

**PERFORMANCE:**

Application field	Gas of the 2 <sup>nd</sup> and 3 <sup>rd</sup> family, according to EN 437
Nominal pressure rating	MOP 0.5
Temperature application field	-20..+60° C
Thermal shut-off device response	+95° C ±5° C
High temperature resistance	Up to 650° C for 30 minutes
Connections	Thread R1/2" – plug for safety hose DIN 3383-1
Tightness test frequency	100%
Functional test frequency (open-close)	100%

Signed for and on behalf of:

Luca Istruiti, Quality Manager

Brescia 03/09/2025

(Signature or equivalent authorized by the issuer)